



APPLICATION:

Single Plastic Conduit ($d \leq 32$)

ID:

CFS-FS: 11

INFORMATION:

- Not to scale
- All units are in millimetres
- Tested according EN 1366-3
- Approval ETA - 18/1024

CFS-FS M Flexible Seal

REV:


DATE:

02

02/2025

Fire Rating up to EI 60

Page 1/1




Acoustics rating: $R_w = 50$

Maximum opening dimensions: 1200x500mm. For blank openings see approval documents.

*First support and ancillary products should be capable of achieving the same fire performance as the seal and supporting structure.

**Comprising timber or steel studs. Wall construction itself has been classified according to EN 13501-2.




Ref.	Service Type (See service standard detail for more specific information)	Distance (mm) [†]
b ₁	To top of opening	≥70 ^{††}
b ₂	To side of opening	≥30 ^{††}
b ₃	To bottom of opening	≥35 ^{††}
C ₁	To metal pipe w/ mineral wool insulation	≥0
C ₂	To metal pipe w/ combustible insulation	≥30
C ₃	To cables/cable bundle/cable carrier	≥50 ^{†††}
C ₄	To cable trunking w/ mineral wool insulation	≥50
C ₅	To combustible plastic pipe w/ Hilti CFS-B	≥30
C ₆	To MLC (Aluminium composite) pipe w/ or w/o insulation	≥50
C ₇	To rectangular PVC Duct w/ Hilti CFS-B	≥50
C ₈	To CiimaSplit bundle	≥50
C ₉	To CPVC or TracPipe®	≥50
C ₁₀	To combustible plastic pipe & conduit w/o addn. protection	≥50
C ₁₁	To conduit w/ Hilti CFS-B	≥50

[†]All distance values can be horizontal, vertical or diagonal.

^{††}b₁, b₂, b₃ = 30mm if no movement is required.

^{†††}For cables d > 21mm, a min distance of 100mm from other services is required.

Single Plastic Conduit ($d \leq 32$)			
Material	Diameter [mm]	Addn. Protection	Classification
Single conduit w/ or w/o cable	$d \leq 32$ [‡]	N/A	EI 60 (U/U)
Notes: Conduit to extend a minimum of 300mm on either side of the wall surface			
[‡] Flexible/Pliable Max Wall Thickness: 4.25 mm			
[‡] Rigid Conduit Max Wall Thickness: 2.0 mm			



- The application limits on this detail are for guidance purposes only. For more detailed information based on the full range of available test results please contact the Hilti Technical Advisory Service.
- The product and application has been assessed as a minimum to the BS 476 standard. It may have additional European and worldwide testing. Please contact Hilti for further information.
- All installations should be carried out in accordance with Hilti's installation instructions and by competent & experienced installers using Hilti branded products.
- All services are to be correctly and adequately supported to prevent collapse and distortion.

Hilti (Gt. Britain) Limited | No 1, Circle Square | 3 Symphony Park | Manchester | M1 7FS

Freephone: 0800 886 100 | Website: www.hilti.co.uk

LEGAL NOTICE: This template contains Hilti Intellectual Property which is legally protected, including Community registration of Hilti trademarks. For use only by Hilti customers and in conjunction with Hilti products. No third party use/products is authorised and breaches Hilti's intellectual property rights. Hilti accepts no responsibility for unauthorized use and reserves all rights to take legal action to enforce its rights in law.